



SUPPLEMENTAL BULLETIN NO. 1

**DESIGN, SUPPLY, DELIVERY, INSTALLATION, TESTING AND
COMMISSIONING OF THREE PHASE SUBMARINE LINE CABLE FROM
BRGY. DACULAN, ESTANCIA TO BRGY. MANLOT, CARLES, FROM
BRGY. MANLOT TO BRGY. TALINGTING, CARLES AND FROM BRGY.
PUNTA BATUANAN TO BRGY. SAN FERNANDO, CARLES, ILOILO
(TURN KEY)**

(Invitation to Bid No. 2405, S. 2024)

To : All Bidders
: Members, BAC & TWG
: Others Concerned

Relative to the Design, Supply, Delivery, Installation, Testing and Commissioning of Three Phase Submarine Line Cable from Brgy. Daculan, Estancia to Brgy. Manlot, Carles, from Brgy. Manlot to Brgy. Talingting, Carles and from Brgy. Punta Batuanan to Brgy. San Fernando, Carles, Iloilo (Turn Key), published/advertised on October 21, 2024 in ILECO 3 and NEA websites, likewise, on October 21, 2024 in The Manila Times, please be informed of the following amendments, revisions, modifications and clarifications to the Invitation to Bid No. 2405, S. 2024 "Design, Supply, Delivery, Installation, Testing and Commissioning of Three Phase Submarine Line Cable from Brgy. Daculan, Estancia to Brgy. Manlot, Carles, from Brgy. Manlot to Brgy. Talingting, Carles and from Brgy. Punta Batuanan to Brgy. San Fernando, Carles, Iloilo (Turn Key)" as discussed during the Pre-Bid Conference held last October 29, 2024 at 8:30 in the morning;

1. The Material Specifications is hereto amended/corrected on the attached Revised Terms of Reference.
2. Bid offer must be priced per item/material since it will be submitted to NEA during liquidation.
3. All certifications and other reports and documents stated in the Terms of Reference must be attached to the Technical Documents for submission during the Opening of Bids.
4. The BAC shall be given a copy of the photo and video documentation during all stages of the project.
5. The warning buoys must be in 6 sites/locations.
6. Submarine cable must be suitable for submersion up to 50 meters depth of salty water.



ILOILO III ELECTRIC COOPERATIVE, INC. **BIDS AND AWARDS COMMITTEE (BAC)**

Tel. No. (033) 392 - 0202

Email Address: bac.ileco3@gmail.com



7. The Bill of Materials should be per Island.
8. The following forms/templates are herewith attached for the bidders:
 - a. Bid Form for the procurement of Goods
 - b. Bid Form for the procurement of Infrastructure Projects.
 - c. Price Schedule for Goods offered from Within the Philippines
 - d. Price Schedule for Goods offered from Abroad
 - e. Cash Flow by Quarter
 - f. Progress Report

THE BIDS AND AWARDS COMMITTEE:

By:

ENGR. ELMA B. FUENTES
Chairperson, BAC